

SEPTIC SYSTEM INTEGRITY TEST

Legal Description

Park _____ Subdivision _____ Lot ____ Block ____ Property # _____

Lessee Information

Name(s): _____

Cottage Address: _____

Phone No. _____ Email: _____

Integrity Test

I/We consent that the park proceed with an integrity test of our septic system.

This will confirm that as of *(date)* _____ the tank has been filled to the top of the tank/bottom of collar per the park official's instructions and the cottage will be vacant for at least the next 24 hours.

By signing below, I/We acknowledge that the test of our septic system does not create any warranty regarding the merchantability of the system, nor does this test guarantee the performance of our septic system after the date on which it was tested; any failure of the septic system is the responsibility of the cottage owner.

Lessee (Signed)

Date

Lessee (Signed)

Date

TO BE COMPLETED BY PARK OFFICIAL

The septic system located at the cottage address above has been tested and the following results were found:

o 1st Measurement Result _____ Date _____ Time _____

o 2nd Measurement Result _____ Date _____ Time _____

Failed: Test showed a fluctuation in the amount of liquid in the tank therefore it is deemed the septic system does not meet Canadian Standards Association (CSA) and the *Provincial Park Regulations, 1991* and therefore must be repaired/removed.

Passed: Test showed no fluctuation in the amount of liquid in the tank therefore the park finds the septic system listed above satisfies CSA and the *Provincial Park Regulations, 1991*. This septic system will be subject to retesting in a minimum of 5 years.

Park Official Signature _____

Date _____

Revised 10/21